

Case 13 Detailed View: Consider Seven Days Starting Hour 192 and Ending Hour 360

NYCA

Hourly Load/Generation Balance by Resource Type

CLCPA Case - Winter - CCP2 Resource Set - Wind Lull - State-wide

Aggregate Load in Period (MWh)	27,322,037
Aggregate Gen in Period (MWh)	32,527,026
Gen Surplus/Deficit (MWh)	5,204,989
Hours with Aggregate Gen Deficit	13
Hours with Load Loss in any Zone	13
Aggregate Zonal Load Loss (MWh)	14,404

